

Installation Instructions

NAPKED-5040HW / NAPKED-5060HW / NATLED 5040HW / NATLED-5075HW

Class II Low Voltage Dimmable Driver / Enclosure

READ PRIOR TO ATTEMPTING INSTALLATION
ALWAYS TURN OFF MAIN POWER BEFORE INSTALLATION
INSTALLATION SHOULD BE CARRIED OUT BY YOUR LOCAL ELECTRICIAN

⚠ IMPORTANT - This equipment is intended to be installed only by qualified personnel. The installation must be made in accordance with the current edition of the National Electrical Code and all applicable state and local building codes. The final installation must be approved by the appropriate, qualified electrical/building inspector(s). Improper installation may result in a fire or electrical hazard. Be sure the electrical power to the circuit has been disconnected before installing this electrical system.


⚠ IMPORTANT - Cet équipement est destiné à être installé uniquement par du personnel qualifié. L'installation doit être faite conformément à l'édition actuelle du Code national de l'électricité et à tous les codes de construction locaux et nationaux applicables. L'installation finale doit être approuvée par un ou plusieurs inspecteurs qualifiés en électricité / bâtiment. Une installation incorrecte peut entraîner un incendie ou un risque électrique. Assurez-vous que l'alimentation électrique du circuit a été déconnectée avant d'installer ce système électrique.

CAUTION:

- All installations should comply with National and local electric codes
- This is intended to be installed with compatible Nora Lighting 12V or 24V systems
- Read all instructions thoroughly before starting installation
- Turn off power before installing the system




PACKAGING CONTENTS



Driver / Enclosure



Strain Relief



10' Power Line Connector

WIRING INSTRUCTIONS

1. Fasten driver housing using two screws (not included) through key hole slots. (Figure 1)
2. Attach ground wire to enclosure.
3. Connect line voltage wires to driver's black and white input leads per local electrical code. (Figure 2)
4. Connect low voltage wires to driver's red and black output leads using supplied strain relief. (Figure 2)
5. **OPTIONAL:** Connect Nora's 10' power line connector (included) to driver output leads using supplied strain relief.
Black (driver lead) - Ribbed wire (10' power line connector)
Red (driver lead) - Smooth wire (10' power line connector)
6. Secure driver box cover.

NOTE: Consult Nora website for compatible dimmers.

