

Installation Instructions

NTE-864

MAX Mini LED Track Head

READ PRIOR TO ATTEMPTING INSTALLATION
ALWAYS TURN OFF MAIN POWER BEFORE INSTALLATION
INSTALLATION SHOULD BE CARRIED OUT BY YOUR LOCAL ELECTRICIAN

INPUT RATING	OUTPUT RATING
13W 120VAC 60Hz	36VDC 310mA

IMPORTANT SAFETY INSTRUCTION (READ ALL INSTRUCTIONS)

When installing or using this luminaire, basic safety precautions should always be followed, including the following:

For use with Nora "NT" track system.

CONSIGNES DE SÉCURITÉ IMPORTANTES (LISEZ TOUTES LES INSTRUCTIONS)

Lors de l'installation ou de l'utilisation de ce luminaire, il vous faut toujours respecter les consignes de sécurité de base, y compris les suivantes.





À utiliser avec le système de chenilles Nora "NT".

- Do not install this luminaire in damp or wet locations / N'installez pas ce luminaire dans des emplacements humides ou mouillés
- Do not install any part of this luminaire less than 5 feet above the floor / N'installez aucune section de ce luminaire à moins de 1,52 m (5 pi) au-dessus du sol
- Do not install any luminaire assembly closer than 6 inches from any curtain, or similar combustible material / N'installez aucun luminaire à moins de 15,24 cm (6 po) de tout rideau ou autre matériau combustible similaire
- Disconnect electrical power before adding to or changing the configuration of the track / Coupez l'alimentation électrique avant d'ajouter à la configuration du rail ou de la modifier
- Do not attempt to energize anything other than lighting track luminaires on the track. To reduce the risk of fire and electric shock, do not attempt to connect power tools, extension cords, appliances, and the like to the track / Ne tentez pas d'alimenter un appareil autre que des luminaires pour rail d'éclairage sur le rail. Pour réduire les risques d'incendie et de choc électrique, n'essayez pas de brancher des outils électriques, des rallonges, des appareils ménagers et autres produits du genre sur le rail.

SAVE THESE INSTRUCTIONS / CONSERVEZ CES INSTRUCTIONS

INSTALLATION

1. Turn off power to track before beginning installation.
If installing in single circuit track, proceed to step 3.
2. If installing in two circuit track, raise "Circuit Contact" on the track head adapter by using a flathead screwdriver to lift up contact to second circuit. (Figure 1)
3. Align the track head adapter and contacts parallel with track.
4. Insert the adapter into the track and twist the adapter towards the polarity line until the latch locks into track. (Figure 2)



Installation Instructions

NTE-864/L

MAX Mini LED Track Head with L-Style Adapter

READ PRIOR TO ATTEMPTING INSTALLATION
ALWAYS TURN OFF MAIN POWER BEFORE INSTALLATION
INSTALLATION SHOULD BE CARRIED OUT BY YOUR LOCAL ELECTRICIAN

INPUT RATING	OUTPUT RATING
13W 120VAC 60Hz	36VDC 310mA

IMPORTANT SAFETY INSTRUCTION (READ ALL INSTRUCTIONS)

When installing or using this luminaire, basic safety precautions should always be followed, including the following:

For use with Lightolier "Lytespan" track system.

CONSIGNES DE SÉCURITÉ IMPORTANTES (LISEZ TOUTES LES INSTRUCTIONS)

Lors de l'installation ou de l'utilisation de ce luminaire, il vous faut toujours respecter les consignes de sécurité de base, y compris les suivantes.

À utiliser avec le système de chenilles Lightolier "Lytespan".

- Do not install this luminaire in damp or wet locations / N'installez pas ce luminaire dans des emplacements humides ou mouillés
- Do not install any part of this luminaire less than 5 feet above the floor / N'installez aucune section de ce luminaire à moins de 1,52 m (5 pi) au-dessus du sol
- Do not install any luminaire assembly closer than 6 inches from any curtain, or similar combustible material / N'installez aucun luminaire à moins de 15,24 cm (6 po) de tout rideau ou autre matériau combustible similaire
- Disconnect electrical power before adding to or changing the configuration of the track / Coupez l'alimentation électrique avant d'ajouter à la configuration du rail ou de la modifier
- Do not attempt to energize anything other than lighting track luminaires on the track. To reduce the risk of fire and electric shock, do not attempt to connect power tools, extension cords, appliances, and the like to the track / Ne tentez pas d'alimenter un appareil autre que des luminaires pour rail d'éclairage sur le rail. Pour réduire les risques d'incendie et de choc électrique, n'essayez pas de brancher des outils électriques, des rallonges, des appareils ménagers et autres produits du genre sur le rail.

SAVE THESE INSTRUCTIONS / CONSERVEZ CES INSTRUCTIONS

INSTALLATION

INSTALLATION INSTRUCTIONS TO SINGLE CIRCUIT TRACK SYSTEM:






1. Turn off power to track before beginning installation.
2. Insert into LYTESPAN TRACK. (Figure 1) Locking lever must be on the same side of track as bead.
3. Rotate fitting 90° clockwise. (Figure 2)
4. Rotate fitting until locking lever snaps and locks in place. (Figure 3)
5. **TO REMOVE:** Depress locking lever, then rotate fitting 90° counterclockwise.

FOR ADAPTER WITHOUT THE LOCKING LEVER: Insert the adapter into the track and twist the adapter and ground contact towards the polarity groove. (Figure 5)

INSTALLATION INSTRUCTIONS TO TWO CIRCUIT TRACK SYSTEM:

1. Turn off power to track before beginning installation.
2. Brass contact can be raised or lowered. (Figure 4)
3. Broken line indicates position for one circuit or lower circuit of two circuit track system.
To convert attachment fitting for upper circuit of two circuit track, raise brass contact to high position by lifting contact as high as stop permits and contact clicks into place.

FOR ADAPTER WITHOUT THE LOCKING LEVER: Raise "Positive Contact" by inserting the screwdriver under the contact and lifting upward. (Figure 4) Insert the adapter into the track and twist the adapter and ground contact towards the polarity groove. (Figure 5)



Installation Instructions

NTE-864/J

MAX Mini LED Track Head with J-Style Adapter

READ PRIOR TO ATTEMPTING INSTALLATION
ALWAYS TURN OFF MAIN POWER BEFORE INSTALLATION
INSTALLATION SHOULD BE CARRIED OUT BY YOUR LOCAL ELECTRICIAN

INPUT RATING	OUTPUT RATING
13W 120VAC 60Hz	36VDC 310mA

IMPORTANT SAFETY INSTRUCTION (READ ALL INSTRUCTIONS)

When installing or using this luminaire, basic safety precautions should always be followed, including the following:

For use with Juno "T" track system.

CONSIGNES DE SÉCURITÉ IMPORTANTES (LISEZ TOUTES LES INSTRUCTIONS)

Lors de l'installation ou de l'utilisation de ce luminaire, il vous faut toujours respecter les consignes de sécurité de base, y compris les suivantes.

À utiliser avec le système de chenilles Juno "T".

- Do not install this luminaire in damp or wet locations / N'installez pas ce luminaire dans des emplacements humides ou mouillés
- Do not install any part of this luminaire less than 5 feet above the floor / N'installez aucune section de ce luminaire à moins de 1,52 m (5 pi) au-dessus du sol
- Do not install any luminaire assembly closer than 6 inches from any curtain, or similar combustible material / N'installez aucun luminaire à moins de 15,24 cm (6 po) de tout rideau ou autre matériau combustible similaire
- Disconnect electrical power before adding to or changing the configuration of the track / Coupez l'alimentation électrique avant d'ajouter à la configuration du rail ou de la modifier
- Do not attempt to energize anything other than lighting track luminaires on the track. To reduce the risk of fire and electric shock, do not attempt to connect power tools, extension cords, appliances, and the like to the track / Ne tentez pas d'alimenter un appareil autre que des luminaires pour rail d'éclairage sur le rail. Pour réduire les risques d'incendie et de choc électrique, n'essayez pas de brancher des outils électriques, des rallonges, des appareils ménagers et autres produits du genre sur le rail.

SAVE THESE INSTRUCTIONS / CONSERVEZ CES INSTRUCTIONS

INSTALLATION

INSTALLATION INSTRUCTIONS TO SINGLE CIRCUIT TRACK SYSTEM:

NOTE: All Juno track sections have an embossed line (Figure 1) that indicates the track polarity. All track fixture adapters have raised arrows (Figure 2) that point to the polarity line when they are installed on the track section.

1. To attach fixture to single circuit track, insert "Adapter Contacts" (Figure 2) into track channel. Track fixture should be off.
2. Rotate adapter 1/4 turn (90°) so that polarity arrows point at the polarity line on the track.
3. Juno track fixture adapter have an on-off switch. Switch "on" position is opposite "Locking" lever.

FOR ADAPTER WITHOUT THE LOCKING LEVER: Insert the adapter into the track and twist the adapter and ground contact towards the polarity groove. (Figure 5)

INSTALLATION INSTRUCTIONS TO TWO CIRCUIT TRACK SYSTEM:

NOTE: For two circuit installation, the "Positive Contact" - (marked "P" - see Figure 3) must be in lower position for single circuit and in raised position for two circuit.

1. To install track fixture on 2nd (upper) circuit, raise "Positive Contact" by inserting a thin screwdriver under the contact and lifting upward (Figure 3).
2. Insert a "Contact Support" under the raised "Positive Contact" (Figure 4). (These "Positive Contact Supports" are supplied with all Juno Two Circuit Track sections.)
3. To attach fixture to two circuit track, insert "Adapter Contacts" (Figure 2) into track channel. Track fixture should be off.
4. Rotate adapter 1/4 turn (90°) so that polarity arrows point at the polarity line on the track.
5. Juno track fixture adapter have an on-off switch. Switch "on" position is opposite "Locking" lever.

FOR ADAPTER WITHOUT THE LOCKING LEVER: Raise "Positive Contact" by inserting the screwdriver under the contact and lifting upward. (Figure 3) Insert the adapter into the track and twist the adapter and ground contact towards the polarity groove. (Figure 5)

