
Installation Instructions

NAPC-3S

Square Extension Collar for 3" Apollo Housings


READ PRIOR TO ATTEMPTING INSTALLATION
ALWAYS TURN OFF MAIN POWER BEFORE INSTALLATION
INSTALLATION SHOULD BE CARRIED OUT BY YOUR LOCAL ELECTRICIAN


ITEM NUMBER	CEILING THICKNESS RANGE	COMPATIBLE HOUSING	
NAPC-3S05	0.5" to 0.875"	NHAP-3S, NHAPIC-3S	
NAPC-3S10	0.875" to 1.25"	NHAP-3S, NHAPIC-3S	
NAPC-3S15	1.25" to 1.625"	NHAP-3S, NHAPIC-3S	
NAPC-3S20	1.625" to 2"	NHAP-3S, NHAPIC-3S	



INSTALLATION INSTRUCTION

To replace existing housing collar; loosen (4) set screws with hex bit (included) and remove existing collar.





A TURN OFF MAIN POWER BEFORE INSTALLATION

